



FOUNDATION SLEEVE REQUIREMENTS:

1. SLEEVE SHALL BE 4" SCHEDULE 40 PVC, AND SHALL EXTEND 3" MINIMUM BELOW FOOTING AND 3" MINIMUM ABOVE FLOOR SLAB OR STEM WALL.
2. SLEEVE MAY BE UTILIZED AS THE ELECTRICAL SERVICE CONDUIT WHEN STRUCTURE REQUIRES A 4" SERVICE.



**CITY OF
BOULDER CITY, NV**
**PUBLIC WORKS
DEPARTMENT**
**ENGINEERING
DIVISION**

**STANDARD DRAWING
ELECTRICAL REQUIREMENTS**

ELECTRICAL SERVICE FOUNDATION SLEEVE

CREATED BY:
C. CROFT
ISSUE DATE:
12/15/15
FILE NAME:
BC-ELEC-SLEEVE
SHEET:
1 OF 1